


REF. SWITCHBOARD	[K.E.K.]	1	2	3	4	5	6	7	8	9	
PURCHASER						SWITCHBOARD CHARACTERISICS					
						UPSTREAM PLANT					
						VOLTAGE [V] 400 FREQ. [Hz] 50					
						SWITCHBOARD RATED CURRENT [A]					
ORDER						SWITCHBOARD PERSPECTIVE CURRENT [kA] 9.6					
						NEUTRAL SYSTEM TNS					
						BUSBAR SIZE					
						In [A] Icc [kA]					
SWITCHBOARD						STRUCTURE METALLICA					
						INSULATION CLASS IP 45					
						REFERENCE STANDARD					
						MOULDED CASE CIRCUIT BREAKERS <input checked="" type="checkbox"/> — CEI EN 60947-2					
KUADRI ELEKTRIK KRYESOR						MINIATURE CIRCUIT BREAKERS <input checked="" type="checkbox"/> — CEI EN 60947-2					
						<input type="checkbox"/> — CEI EN 60898					
						STRUCTURE <input checked="" type="checkbox"/> — CEI EN 60439-1					
						<input type="checkbox"/> — CEI 23-48 CEI 23-49 CEI 23-51					
 www.fishtaelectric.com e-mail: info@fishtaelectric.com mob.+355 684043450 tel.+355 22243163		CUSTOMER ADISA			PROJECT Ing. Mario FISHTA			FILE Progetto_[Q00]_[K.E.K.].dwg			
					ARCHIVE Ing.Hafete KINKA			DATE 19-Nov-18		REVISION R0.0	
					DESIGNER Ing. Igli SHAQIRI			PAGE 1		NEXT 2	
					PLANT Agjencia e Ofrimit te Sherbimeve Publike te Integruara Kombinat, Tirane			TABLE			