


REF. SWITCHBOARD	[K.E.UPS]	1	2	3	4	5	6	7	8	9		
PURCHASER						SWITCHBOARD CHARACTERISICS						
						UPSTREAM PLANT [UPS]						
						VOLTAGE [V] 400 FREQ. [Hz] 50						
						SWITCHBOARD RATED CURRENT [A]						
ORDER						SWITCHBOARD PERSPECTIVE CURRENT [kA] 8.2						
						NEUTRAL SYSTEM TNS						
						BUSBAR SIZE In [A] Icc [kA]						
						STRUCTURE METALLICA						
SWITCHBOARD KUADRI ELEKTRIK UPS						INSULATION CLASS IP 45						
						REFERENCE STANDARD						
						MOULDED CASE CIRCUIT BREAKERS <input checked="" type="checkbox"/> — CEI EN 60947-2						
						MINIATURE CIRCUIT BREAKERS <input checked="" type="checkbox"/> — CEI EN 60947-2 <input type="checkbox"/> — CEI EN 60898						
						STRUCTURE <input checked="" type="checkbox"/> — CEI EN 60439-1 <input type="checkbox"/> — CEI 23-48 CEI 23-49 CEI 23-51						
 <div>www.fishtaelectric.com e-mail: info@fishtaelectric.com mob.+355 684043450 tel.+355 22243163</div>		CUSTOMER ADISA			PROJECT Ing. Mario FISHTA		FILE Progetto_[Q02]_[K.E.UPS].dwg					
					ARCHIVE Ing.Hafete KINKA		DATE 19-Nov-18		REVISION R0.0			
		PLANT Agjencia e Ofrimit te Sherbimeve Publike te Integruara Kombinat, Tirane			DESIGNER Ing. Igli SHAQIRI		PAGE 1		NEXT 2			
							TABLE					